



PLAN VIEW



(NOTE: BALLAST NOT SHOWN)

NOTES

1. STORAGE MUST BE PROVIDED FOR 24 HOURS WORTH OF FLOWS AS DETERMINED BY SECTION 2.21, AS MEASURED FROM THE HEIGHT OF THE ALARM LEVEL.
2. PUMP SHALL BE INSTALLED ACCORDING TO MFG. SPECS & RECOMMENDATIONS.
3. HIGH WATER ALARM & MANUAL OPERATING SWITCH SHALL BE INSTALLED IN ACCESSIBLE LOCATION INSIDE THE DWELLING AND IN COMPLIANCE WITH LOCAL BLDG. CODE.
4. ALARM SHALL BE POWERED BY A CIRCUIT SEPARATE FROM THE PUMP POWER.
5. ALL INLETS & OUTLETS SHALL BE SEALED WITH HYDRAULIC CEMENT.
6. PUMP CHAMBERS SHALL BE SEALED AND SHALL BE WATERTIGHT.
7. THE FLOOR OF THE PUMP TANK SHALL BE SLOPED TOWARDS THE PUMP WITH CAST IN PLACE CONCRETE.
8. PUMP TANK CONSTRUCTION AND INSTALLATION SHALL CONFORM IN EVERY WAY TO 310 CMR 15.231 UNLESS OTHERWISE NOTED.



SECTION VIEW B-B

SEWER STORAGE CHAMBER WITH EXTERNAL PUMP

N.T.S.