



TOWN OF ANDOVER

Department of Public Works
5 Campanelli Drive
Andover, MA 01810
(978) 623-8700
www.andoverma.gov

MEMORANDUM

TO: Jacki Byerley, Planner
FROM: Art Martineau, P.E., Town Engineer *AM*
SUBJECT: 22 William St / William Wood Way – Small Drainage Area Near William St
DATE: October 19, 2022

This memo is to communicate to the Planning Board that DPW supports allowing a small area of runoff that would result from the above referenced project to flow onto William St without the need for further mitigation. This issue is mentioned in Horsley Witten's (HW) stormwater peer review letter dated 10/13/22 under item 2.C on page 3 of 12. In the letter, HW suggests The Board may choose to confirm that the Town Engineer has no objections to the minimum runoff. This memo should serve as such confirmation.

The runoff area in question is approximately 1,700 SF from a project area of roughly 140,000 SF, and will result in a calculated flow of 0.1 cubic feet per second during 25-year storm event. In this particular case, and in my opinion, the impact is inconsequential enough as to not burden the existing drainage system in William St and does not warrant burdening the applicant with the need to build infrastructure for further mitigation.