



December 28, 2022

Thomas Carbone
Director of Public Health
Town Offices
36 Bartlet Street
Andover, MA 01810

Re: 1320 South St.
BatteryStorage Facility

Dear Mr. Carbone:

New Leaf Energy is pleased to submit the attached information addressing the comments sent December 20, 2022.

Health Department Comment 1: New Leaf has addressed all concerns brought forth by the Town.

Health Department Comment 2: Sound Monitoring Plan - New Leaf has added all recommended verbiage to the Sound Monitoring Plan put forth but one. Weekly reports are unnecessary due to the nature of the project. There is no "ramp up" for this system. There will be a commissioning phase prior to commercial operation, but sound monitoring at this phase will not provide valuable data because it will not reflect operational conditions. We propose that monitoring be performed within 1 month of commercial operation, with the report provided to the town within 2 months, to provide sufficient time to compile the data. Please see the updated Sound Monitoring Plan attached.

Health Department Comment 3: Funds for Sound Monitoring - New Leaf agrees to this.

Health Department Comment 4: Conditions of approval - New Leaf agrees to this.

With this letter and enclosed documents, we feel all outstanding items have been addressed via the submitted information or by conditions New Leaf is amenable to being placed on the project. If you have any questions regarding the above, please do not hesitate to call.

Sincerely,

A handwritten signature in cursive script that reads "Carli Shroyer".

Carli Shroyer
Civil Engineer
New Leaf Energy